



- NOTES:**
1. ALL INSTALLATION CONDUCTORS ARE TO BE AWG 14, TYPE MTW, 600VAC, 105°C. MULTISTRAND, EXCEPT TWISTED SHIELDED PAIRS AND AS NOTED.
 2. UNLESS COLOR CODED, ALL A.D.E. INSTALLED CONDUCTORS ARE TO BE GREY AND MUST BE IDENTIFIED BY WIRE MARKER AT EACH CONNECTION POINT.
 3. TRANSIENT VOLTAGE PROTECTION INTEGRAL TO 65A ALTERNATOR.
 4. FUEL INJECTION LEADS 494 AND 497 USED ON 1066'S ONLY.
 5. CONNECT 911 TO 937 AS SHOWN FOR ISOCRONOUS OPERATION.
 6. GLOW PLUG LEADS TO BE AWG 16, HIGH TEMPERATURE CABLE.
 7. TOTAL BATTERY/ALTERNATOR CABLE RUN TO BE 8 FEET, MAX.

D.C. Wiring -
12 Volt Standard Ground
Drawing D-3956

Drawings subject to change without notice